

3 Capacity tables

3 - 1 Cooling/Heating capacity tables

1
3

COOLING

Model	Tamb (°C)	20		25		30		35		40		43	
	LWE (°C)	CC	PI	CC	PI	CC	PI	CC	PI	CC	PI	CC	PI
005	7	6.01	1.56	5.73	1.75	5.43	1.95	5.12	2.16	4.80	2.39	4.59	2.53
	11	6.81	1.57	6.50	1.77	6.17	1.98	5.83	2.21	5.30	2.32	4.98	2.38
	13	7.23	1.57	6.90	1.78	6.56	2.00	6.20	2.23	5.56	2.28	5.18	2.30
	16	7.88	1.56	7.54	1.78	7.17	2.01	6.79	2.26	5.95	2.22	5.46	2.18
	20	8.80	1.55	8.42	1.79	8.03	2.03	7.63	2.29	6.48	2.13	5.82	1.99
006	7	7.15	2.05	6.84	2.28	6.50	2.52	6.13	2.77	5.35	2.68	4.89	2.59
	11	8.09	2.09	7.73	2.34	7.34	2.59	6.94	2.87	5.84	2.62	5.21	2.43
	13	8.57	2.11	8.20	2.36	7.79	2.63	7.36	2.91	6.09	2.59	5.36	2.34
	16	9.33	2.13	8.92	2.40	8.49	2.68	8.03	2.97	6.46	2.53	5.57	2.20
	20	10.4	2.16	9.9	2.44	9.48	2.73	8.99	3.04	6.96	2.44	5.82	1.99
007	7	8.24	2.43	7.90	2.68	7.52	2.94	7.10	3.23	5.68	2.86	4.87	2.59
	11	9.26	2.49	8.87	2.76	8.45	3.05	7.79	3.31	6.12	2.80	5.18	2.43
	13	9.79	2.52	9.38	2.80	8.93	3.10	8.14	3.36	6.34	2.77	5.33	2.35
	16	10.6	2.57	10.17	2.86	9.69	3.17	8.68	3.41	6.67	2.71	5.55	2.20
	20	11.7	2.63	11.3	2.94	10.75	3.26	9.39	3.48	7.09	2.61	5.80	1.99

HEATING (Peak values)

Model	LWC	30		35		40		45		50	
		HC	PI	HC	PI	HC	PI	HC	PI	HC	PI
005	-15	3.93	1.48	3.67	1.59	3.47	1.71	3.33	1.84	3.25	1.99
	-10	4.65	1.52	4.32	1.65	4.07	1.79	3.89	1.94	3.78	2.10
	-7	5.14	1.54	4.77	1.68	4.49	1.83	4.28	1.99	4.15	2.16
	-2	6.06	1.57	5.62	1.72	5.28	1.88	5.03	2.06	4.87	2.25
	2	6.89	1.57	6.38	1.74	6.00	1.91	5.72	2.11	5.53	2.31
	7	8.03	1.57	7.45	1.75	7.00	1.94	6.68	2.15	6.47	2.37
006	-15	4.87	1.82	4.62	1.94	4.43	2.08	4.30	2.23	4.24	2.40
	-10	5.67	1.88	5.34	2.02	5.09	2.18	4.92	2.36	4.82	2.55
	-7	6.21	1.91	5.83	2.07	5.55	2.24	5.35	2.42	5.23	2.63
	-2	7.23	1.95	6.77	2.13	6.42	2.32	6.17	2.52	6.02	2.75
	2	8.14	1.97	7.61	2.16	7.21	2.37	6.92	2.59	6.74	2.83
	7	9.40	1.98	8.79	2.19	8.32	2.42	7.98	2.66	7.78	2.92
007	-15	5.42	2.06	5.16	2.19	4.97	2.34	4.86	2.51	4.80	2.70
	-10	6.27	2.13	5.93	2.29	5.68	2.46	5.51	2.65	5.42	2.86
	-7	6.84	2.17	6.46	2.34	6.17	2.53	5.97	2.73	5.86	2.95
	-2	7.92	2.22	7.45	2.41	7.10	2.62	6.85	2.85	6.70	3.10
	2	8.9	2.26	8.35	2.46	7.93	2.69	7.65	2.93	7.47	3.20
	7	10.2	2.28	9.58	2.51	9.10	2.76	8.76	3.02	8.56	3.31

HEATING (integrated values*)

Model	LWC	30		35		40		45		50	
		HC	PI	HC	PI	HC	PI	HC	PI	HC	PI
005	-15	3.50	1.40	3.27	1.51	3.09	1.62	2.97	1.75	2.89	1.89
	-10	4.14	1.45	3.85	1.56	3.62	1.70	3.46	1.84	3.36	2.00
	-7	4.52	1.45	4.20	1.58	3.95	1.72	3.77	1.87	3.65	2.03
	-2	5.27	1.46	4.89	1.60	4.59	1.75	4.38	1.92	4.24	2.10
	2	5.92	1.45	5.49	1.60	5.16	1.76	4.92	1.94	4.76	2.13
	7	8.03	1.57	7.45	1.75	7.00	1.94	6.68	2.15	6.47	2.37
006	-15	4.34	1.73	4.11	1.85	3.94	1.98	3.83	2.12	3.77	2.28
	-10	5.04	1.79	4.75	1.92	4.53	2.07	4.38	2.24	4.29	2.42
	-7	5.46	1.80	5.13	1.94	4.88	2.10	4.71	2.28	4.60	2.47
	-2	6.29	1.81	5.89	1.98	5.59	2.15	5.37	2.35	5.23	2.56
	2	7.00	1.81	6.55	1.99	6.20	2.18	5.96	2.38	5.80	2.61
	7	9.40	1.98	8.79	2.19	8.32	2.42	7.98	2.66	7.78	2.92
007	-15	4.82	1.96	4.59	2.08	4.43	2.23	4.32	2.39	4.27	2.56
	-10	5.58	2.03	5.28	2.17	5.06	2.34	4.91	2.52	4.82	2.72
	-7	6.02	2.04	5.69	2.20	5.43	2.37	5.26	2.57	5.15	2.78
	-2	6.89	2.07	6.48	2.25	6.17	2.44	5.96	2.65	5.83	2.88
	2	7.6	2.08	7.18	2.27	6.82	2.47	6.58	2.70	6.43	2.94
	7	10.2	2.28	9.58	2.51	9.10	2.76	8.76	3.02	8.56	3.31

* The integrated heating capacity and power input, is the average heating capacity and power input during 1 cycle. (from end of defrost till end of the next defrost).

4TW56712-1A

SYMBOLS

CC	: Cooling capacity at maximum operating frequency, measured acc. Eurovent 6/C/003-2006 (kW)
HC	: Heating capacity at maximum operating frequency, measured acc. Eurovent 6/C/003-2006 (kW)
PI	: Power input (kW)
LWE	: Leaving Water Evaporator temperature (°C)
LWC	: Leaving Water Condensor temperature (°C)
Tamb	: Ambient temperature (°C) RH=85%

NOTES

- Cooling capacity**
Capacity is according to Eurovent rating standard 6/C/003-2006 and valid for chilled water range Dt = 3–8°C
- Heating capacity**
Capacity is according to Eurovent rating standard 6/C/003-2006 and valid for chilled water range Dt = 3–8°C
- Power input**
Power input is total input according to Eurovent rating standard 6/C/003-2006